

Ohio University Building Asbestos Summary List

Airport- (former EHS Storage Bldg.)	GF	None known
Airport-Avionics Lab	GF	None known
Airport-Busch Terminal	GF	None known - new 2003
Airport-Fuller Training Center	GF	None known
Airport-Operations Bldg.(old)	GF	Demolished, December 2004
Airport-Snyder Terminal	GF	None known -new building in 2002
Airport-Storage (next to EHS Bldg.)	GF	None known
Airport-Tee Hanger	GF	None known
Airport-Zero Hanger	GF	None known
Alden Library	GF	Pipe insulation, tank insulation, pipe fitting insulation, pipe wrap material, floor tile & mastic
Anderson Labs	GF	Floor tile/mastic material (none in small 2002 addition)
Animal Resources Building (ARB) (Old Zoological Research)	GF	Pipe fitting insulation and breeching, floor tile & mastic, dome light paper
Aquatic Center	GF	Floor tile/mastic material, transite panels
Armbruster	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite ceiling panels, transite wall panels, floor tile, fire door insulation
Artificial Turf/Track Building/Stands	GF	None known - new in 2001
Athena Cinema (Court St)	GF	Visible removed after purchase in 2001. Inaccessible materials still possible in walls and floors perhaps? Stage fire curtain still there.
Athens Lumber Yard (Old School House)	GF	None known.....Abatement and demolition in 10/2000. Old school house section relocated out on W. Union by bike path 2/2001, and is now the Habitat for Humanity Offices. New HRTC building built on this site in 2002.
Atkinson	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite ceiling panels, transite wall panels, floor tile, fire door insulation
Baker Center	GF	Floor tile & mastic, acoustical plaster ceilings, thermal system insulation
Bentley	GF	All known removed July 2002, expect transite window panels under wall and roofing tar
Bentley-Annex	GF	None known-new building in 2002
Biddle	RA	All known asbestos removed from the interior Oct. 2003 and window caulk removed Spr, 2004. May be asbestos under floor slab.
Bingham House (Visitor Ctr. Log Cabin)	GF	None known
Biochemistry Lab (W. Union)	GF	None known, new in 2001
Bird Arena (Ice Rink)	GF	Transite vent pipe, expansion joint caulking, window glazing, straight pipe insulation, mudded pipe fittings
Botanical Reseach (greenhouse)	GF	Transite countertop, floor tile, fire doors, transite lab hoods, transite tables & walls (greenhouse only)
Boyd	RA	Pipe insulation, tank insulation, duct insulation, fitting insulation, floor tile/mastic material, fire door insulation

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Branch/Chillicothe/ Bennett Hall	RC	Mudded joints on fiberglass wrapped pipe, vinyl floor tile, ceiling tiles, fireproofing, linoleum, tank insulation. ALL BRANCH CAMPUS INFORMATION NOT UPDATED !
Branch/Chillicothe/ Shoemaker Center	RC	Ceiling tiles, Mudded joints on fiberglass wrapped pipe, tank insulation NOT UPDATED !
Branch/Chillicothe/ Stevenson Hall	RC	Mudded joints on fiberglass wrapped pipe, ceiling tiles, roofing materials, NOT UPDATED !
Branch/Eastern (Belmont)/Shannon Hall	RC	Insulated joints, ceiling tiles, mudded joints on fiberglass wrapped pipe, roofing, vinyl floor tile, NOT UPDATED !
Branch/Ironton	RC	None known, NOT UPDATED !
Branch/Lancaster/ Brasee	RC	Spray applied fireproofing, mudded joints on fiberglass wrapped pipe, ceiling panels, wrapped pipe insulation, vinyl floor, roofing materials, duct insulation, hard plaster, NOT UPDATED !
Branch/Lancaster/ Herrold Hall	RC	Mastic, sink bottom coating, thermal system insulation, NOT UPDATED !
Branch/Zanesville/ Elsan Hall	RC	Mudded joints on fiberglass wrapped pipe, wallboard, acoustical ceiling panels, vinyl floor tile, blackboards, lab insulating pads, roofing material, NOT UPDATED !
Branch/Zanesville/ Littick Hall	RC	Mudded joints on fiberglass wrapped pipe, vinyl floor tile, tank insulation, interior duct insulation, NOT UPDATED !
Branch/Zanesville/ Herrold Hall	RC	None known, NOT UPDATED !
Branch/Zanesville/ Campus Center	RC	None known, NOT UPDATED !
Branch/Zanesville/ Maintenance Bldg.	RC	No information, NOT UPDATED !
Bromley Hall (W. Union)	RA	Floortile, mastic, tank insulation, pipe insulation, duct insulation, heat exchanger insulation, breeching, joint compound, acoustic plaster, glue, gaskets, transite pegboard (Purchased in 2001)
Brough	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite ceiling panels, transite wall panels, floor tile, fire door insulation
Brown	RA	Pipe insulation, duct insulation, fitting insulation, transite ceiling panels, floor tile/mastic material, fire door insulation
Brown House	GF	Linoleum
Bryan	RA	Pipe insulation, floor tile/mastic material, fire door insulation
Bush	RA	Pipe insulation, tank insulation, duct insulation, transite wall panels, floor tile/mastic material, fire door insulation
Cady	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite ceiling panels, transite wall panels, floor tile, fire door insulation
Campus Supply (Old Laundry)	GF	Floor tile/mastic material, heat exchanger insulation
Central Classroom Bldg. (Old Campus Support / Old Ind. Technology)	GF	Floor tiles, black cove base, mastic, window caulking, straight pipe insulation, mudded pipe fittings
Central Food	RA	Exhaust stack insulation, floor tile/mastic material, fire door insulation
Chubb	GF	Insulation, preformed-block insulation, floor tile, fire door, vibration joint connector, duct insulation (duct insulation not in cost estimate, found 2/28/95)
Clippinger Labs	GF	Pipe insulation, pipe fitting insulation, floor tile/mastic, transite fumehood exhaust stacks, tank insulation, lab table tops

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Computer Services Center (Old Chemistry)	GF	None known - Was Old Chemistry building abated in the 80's
Convocation Center	GF	Acoustical plaster ceilings, pipe fitting insulation, floor tile/mastic material, converter tank, hard joints, flanges
Copeland	GF	None known abated when renovatd
Corrosion Center (Multiphase Building on W. Union)	GF	None known, new in '90's
Crawford	RA	Pipe insulation, duct insulation, fitting insulation, transite ceiling panels, floor tile/mastic material, fire door insulation
Crewson House (old Chubb House)	GF	None known
Cutler	GF	Floor tile & mastic, straight pipe insulation, mudded pipe fittings, window caulking, door caulking, room mastic
Dougan	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite wall panels, floor tile/mastic material, fire door insulation
DU House	GF	asbestos abated, demolished 7/99
Edgehill (old EG Maint. Shop)	GF	None known
Edwards Accelerator Lab	GF	Floor tile & mastic, pipe insulation, pipe elbows, acoustical ceiling paint, cement board & pipe
Ellis	GF	Mudded pipe fittings, floor tile, built up roof, pegboard, ceiling tiles, window pane caulking
Ewing House	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite wall panels, transite ceiling panels, floor tile/mastic material, fire door insulation
Facilities Management (Physical Plant) Factory St. Stores	GF	Floor tile, mastic, pipe insulation, incinerator insulation. Env. Services (asbestos) Shop located in this building and may have materials in their shop.
Facilities Management (Physical Plant) . Factory St. Dance Studio Bldg	GF	Rough hard plaster (Trace-neg patches?), window caulk
Facilities Management (Physical Plant) Administration Bldg.	GF	None known
Facilities Management (Physical Plant) Campus Green Grounds Shop	GF	None known
Facilities Management (Physical Plant) Garage	GF	duct insulation tape, floor tile, mastic
Facilities Management (Physical Plant) Shops	GF	Floor tile/mastic
Fenzel	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite wall panels, floor tile/mastic material, fire door insulation
Fire doors	GF, RA, RC	Only some fire doors have been sampled since this can damage them. See EHS for details.
Foster	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite wall panels, floor tile/mastic material, fire door insulation
Galbreath Chapel	GF	Pipe insulation, transite wall panels, floor tile/mastic material

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Gamertsfelder	RA	Pipe insulation, boiler insulation, exhaust stack insulation, transite wall panels, floor tile/mastic material, fire door insulation
Glidden Hall (Music Bldg.)	GF	Mudded pipe fittings, pipe hanger rests, floor tiles, tank insulation, built up roofing, fire doors
Golf Starter House	GF	None known (new 1999)
Gordy	GF	None known.....abated in 90's.
Grosvenor	GF	Pipe insulation, tank insulation, pipe fitting insulation, duct insulation, floor of chase, gasket material, floor tile & mastic, joint compounds
Grosvenor West	GF	None known
Grounds Garage (lower campus)	GF	None known - built new
Grover Center	GF	Most all abated in renovation 4/99, except pipe troughs buried in concrete floors, expansion joint caulk
Haning	GF	Floor tile & mastic, carpet adhesive, wall & ceiling plaster (very complicated situation), drywall mudding, thermal system insulation
Heating Plant (Laushe)	GF	Low/high pressure steam pipe insulation, condensate, boiled water, blowdown waste water, drain line, pipe insulation; tank insulation; insulated fittings; transite ceiling panels, galbestos paint on siding
Heating Plant (old) Substation	GF	All above ground removed by Fall, 1999.....except tunnel, under transformer room into mechanical room, still has some acm pipe insulation on it....tunnel may be unstable and needs looked at by engineer before entry.
Hebberdsville Farm (off Rt 32/50 outside of town)	GF	Unknown - never surveyed, acquired in 2001
Hoover House	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite ceiling panels, transite wall panels, floor tile/mastic, fire door insulation
House - 185-187 W. Union	GF	Abated and demolished 7/01
House - 203 W. Union	GF	Abated and demolished 4/01
House - 45? Maplewood	GF	Unknown - never surveyed, has duct tape
House - 8225, 8225A Dairy Lane	GF	Unknown - never surveyed (white house with yellow shutters)
House -193/195 W. Union	GF	Coating on roof, shingles (abated and demolished around 1999- 2000)
House -8133 Dairy Lane	GF	None known (brick house)
House- Dairy Lane X4	GF	Blue House: paper in electric boxes, linoleum, drywall joint compound, roof shingles and tar / White House: paper behind electric boxes, floor tile, hard plaster/ Left A-frame Cottage: textured ceiling, linoleum / Right A-frame Cottage-linoleum (these houses sold and moved off site and are no longer there)
House-189/191 W. Union	GF	transite siding, floor sheating (abated and demolished around 1999- 2000)
House-197 W. Union St.	GF	Duct tape, duct paper, transite, linoleum (abated and demolished around 1999- 2000)
House-29 Moore Street	GF	Abated and demolished in 2000
House-33 Moore Street	GF	Roof shingles, roof tar, paper around heat ducts (abated and demolished 2000)
House-Elmwood 66	GF	Duct wrap, linoleum, sold 2000-2001
House-Miller-25 Factory St.	GF	Demolished
House-Old Coach Rd.	GF	Duct joint tape, floortile, linoleum

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Hudson Health Center	GF	Floor tile, linoleum, ceiling tile, insulation (some buried, inaccessible in walls), hard covered molding, and fittings
Human Resources & Training Center (HRTC)		None known - new in 2002.
Innovation Center (W. State St)	GF	None known - new in 2003.
Irvine	GF	Mudded pipe fittings, floor tile mastic, floor tile stripping, tank insulation, roof parapet caulk, sink undercoating, slate countertop, duct seam putty
James	RA	Fitting insulation, transite wall panels, floor tile/mastic material, fire door insulation
Jefferson	RA	Acoustical ceiling plaster, pipe insulation, fitting insulation, duct insulation, cork ceiling material, transite panels, floor tile/mastic material, fire door insulation
Jennings House	GF	Multi-color linoleum flooring, pipe insulation debris/residue, floor tile
Johnson	RA	None known (all removed 12/2000 during renovation), except maybe the stair entrance fire doors
Kantner	GF	Vermiculite under theatre stage floors only (loose fill).
Konneker Alumni Center	GF	Pipe insulation, floor tile/mastic material
Lasher	GF	Straight pipe insulation, mudded pipe fittings, gasket material, floor tiles, roof parapet tar, exterior caulking, fire doors, flat roof, elevator brake shoes
Library Remote Storage (Hwai Wei Li/Old Gibson Car on Columbus Rd.)	GF	Floor tiles, roof penetration tar, rubber roofing & tar, roof flashing (unless removed in renovation)
Life Sciences Research Facility (LSRF)	GF	None known - new in 2002
Lincoln	RA	Exhaust stack insulation, tank insulation, floor tile/mastic material, fire door insulation
Lindley	GF	Straight pipe insulation, mudded pipe fittings, floor tile, roof parapet caulk, roof penetration tar, roof asphalt shingles, exterior door frame caulk, Formica countertops, built-up roofing, fire doors, fan fabric vibration gaskets
MacKinnon	RA	Pipe insulation, duct insulation, fitting insulation, transite ceiling panels, floor tile/ mastic material, fire door insulation
Martzolff	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite ceiling panels, transite wall panels, floor tile/mastic material, fire door insulation
McCracken	GF	Floor tile & mastic, acoustic plaster ceilings, thermal system insulation
McGuffey	GF	None known
McKee House	GF	Floor tile, duct wrap
Memorial Auditorium	GF	Electrical wire covering, preformed-block pipe insulation (buried above plaster ceilings), fire doors (was not all removed in 1998 renovation)
Mill St. Apartments	RA	Exhaust stack insulation, tank insulation, pipe insulation, fitting insulation, floor tile/mastic material, linoleum, roofing shingles, fire door insulation (Bldgs. E, F, G, H demolish in 10/2000)
Misc. Structures	GF	None known (includes Mill St. microwave shack, field hockey shack, WG baseball field restrooms and pump house, Softball dugouts, IM restrooms, SG field restrooms, Stewart St. white building, visitors lot hut)

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Morton	GF	Pipe insulation, heat exchanger insulation, pipe fitting insulation, floor tile & mastic, transite panels, wood/transite panels in lecture halls
Natatorium (old)	GF	None known.....abated and entire building demolished 8/96.
Nelson Commons	RA	Pipe insulation, exhaust stack insulation, fitting insulation, traniste ceiling panels, floor tile/mastic, fire door insulation, ceiling tile
Oasis	RA	Unknown - purchased by OU, never surveyed
O'Bleness	RA	Exhaust stack insulation, tank insulation, fitting insulation, transite wall panels, floor tile/mastic material, fire door insulation
Outdoors	GF	Transite-like cement water line pipes underground (some near new tennis courts, all other locations unknown)
Park Place 35	GF	Duct insulation, duct wrap
Parks Hall	GF	Pipe fitting insulation, transite splash guard
Peden Stadium (old)	GF	None known
Peden Tower (new)	GF	None known
Perkins	RA	Pipe insulation, tank insulation, duct insulation, transite wall panels, floor tile/mastic material, fire door insulation
Pickering	RA	Pipe insulation, duct insulation, fitting insulation, transite ceiling panels, floor tile/mastic material, fire door insulation
Pilcher House	GF	Floor tile/mastic material, linoleum
Ping Cottage (Old Carriage House)	GF	Duct insulation
Ping Recreation Center	GF	None known
Porter	GF	None known - abated in the early 90's.
President St. Academic Center (PSAC) (Old Innovation Center)	GF	Mastic/floor tiles, coving strip, thermal system insulation
President's House	GF	None known
President's House Garage Apartment	GF	Plaster in garage apartment only (check-borderline positive)
Putnam	GF	None known - abated in late 80's and rest in 2002.
Radio T.V. Communications Bldg.	GF	Transite peg board, floor tile, cementitious fitting insulation, spray applied fire proofing (1st floor-above lobby hard plaster ceiling only & floors 2,3,4 only - rest abated over the years) and debris between original walls (all floors), vibration joints on duct work, asbestos wire covering
Read	RA	None known in building proper, abated in 2003 (insulation still buried in floor slab).
Research & Tech. (RTEC/Old Engineering)	GF	Straight pipe insulation, mudded pipe fittings, floor tile, fume hoods, ceiling tiles, parapet patch tar
Ridges - Outdoor Pursuits Ropes Building	GF	None known, new
Ridges Tunnels (underground)	GF	Pipe insulation between #24-25, other underground ACM was removed
Ridges#01 Administration Bldg., Kennedy Museum (Linn Hall)	GF	165' pipe insulation in attic, roof mastic, floor tile, mastic - rest of building abated during renovation in mid 90's
Ridges#02 Administration Bldg.	GF	Performed-block pipe insulation, cementitious fitting insulation, layered-paper pipe insulation (*amount includes buildings #02, #03, #04, #05, #06, #07, #15 all together)

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Ridges#03 Administration Bldg.	GF	Performed-block pipe insulation, cementitious fitting insulation(*amount includes buildings #02, #03, #04, #05, #06, #07, #15 all together)
Ridges#04 Administration Bldg.	GF	Performed-block pipe insulation, layered-paper pipe insulation, cementitious fitting insulation(*amount includes buildings #02, #03, #04, #05, #06, #07, #15 all together)
Ridges#05 Administration Bldg.	GF	Performed-block pipe insulation, fire door fill material, layered paper pipe insulation, rough coat hard plaster wall, aircell - paper pipe (*amount includes buildings #02, #03, #04, #05, #06, #07, #15 all together)
Ridges#06 Administration Bldg.	GF	Performed-block pipe insulation, layered-paper pipe insulation, performed-block tank insulation (*amount includes buildings #02, #03, #04, #05, #06, #07, #15 all together)
Ridges#07 Administration Bldg.	GF	Performed-block pipe insulation, layered-paper pipe insulation, performed-block tank insulation (*amount includes buildings #02, #03, #04, #05, #06, #07, #15 all together)
Ridges#08 Administration Bldg.	GF	Floor tile & mastic, floor sheeting, drywall finishing compound, thermal system insulation (*amount includes buildings #08, #09, #10 all together)
Ridges#09 Administration Bldg.	GF	Floor tile & mastic, floor sheeting, drywall finishing compound, thermal system insulation (*amount includes buildings #08, #09, #10 all together)
Ridges#10 Administration Bldg.	GF	Floor tile & mastic, floor sheeting, drywall finishing compound, thermal system insulation(*amount includes buildings #08, #09, #10 all together)
Ridges#11 Administration Bldg.	GF	None known
Ridges#12	GF	None known (if all old coolers gone)
Ridges#13 (north) Administration Bldg.	GF	Floor tile & mastic, floor sheeting, ceiling tile, fire door core, asbestos cement shims, thermal system insulation (includes entire north face on the building only)
Ridges#14 Administration Bldg.	GF	Floor tile & mastic, floor sheeting, ceiling tile, fire door core, asbestos cement shims, thermal system insulation (*amount includes #14, #18, and #13 southeast wing only together), window glazing
Ridges#15 Garage	GF	Transite roof shingles (*amount includes buildings #02, #03, #04, #05, #06, #07, #15 all together)
Ridges#16 Administration Bldg.	GF	Floor tile, ceiling tile adhesive, thermal system insulation
Ridges#17 Administration Bldg.	GF	None known
Ridges#18 Administration Bldg.	GF	Floor tile & mastic, floor sheeting, ceiling tile, fire door core, asbestos cement shims, thermal system insulation(*amount includes #14, #18, and #13 southeast only together)
Ridges#19 Administration Bldg.	GF	Floor sheeting, ceiling tile, gasket material associated with heating unit
Ridges#20 Hospital Bldg.	GF	Floor tile & mastic, thermal system insulation (may still use if inside walls ? visible was removed)
Ridges#21 Cottage "O" Bldg. (Voinovich Center)	GF	None known.....removed Febr., 2000. (maybe roofing only?)

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Ridges#22 Cottage "R" Bldg. (ILGARD)	GF	None known.....removed March, 2000 (maybe roofing only?)
Ridges#23 Auditorium	GF	None known
Ridges#24 Cottage "M" Bldg. (EBI, Konneker Lab)	GF	Floor tile, cementitious fitting insulation, preformed block pipe insulation, paper heat shield inside dome light, black asphalt layered roofing material
Ridges#25 Cottage "L" Bldg. (Konneker Labs - EBI)	GF	None known - abated in early 90's during renovation
Ridges#26 Cottage "B" Old Beacon School	GF	Layered-paper & preformed block pipe insul., tar patching on slate roof, floor tile (See EHS about hard plaster walls & ceilings)
Ridges#27 Child Development Center (Daycare)	GF	None known.....former Horsebarn
Ridges#28 Salt Shed	GF	Building removed from site 8/99, demolished as part of Horsebarn Project, no longer there
Ridges#29	GF	Ceiling plaster
Ridges#30 Greenhouse Bldg.	GF	Transite roof shingles on brick building.....glass greenhouse part only demolished in 1999.
Ridges#31 Paint Shop Bldg.	GF	Transite wall panel, performed-block pipe insulation, black tar roofing material
Ridges#32 Water Treatment EHS Rad. Storage	GF	None known (left as far as we know)
Ridges#32 (added new chill water building built in 1999)	GF	None known
Ridges#33 Power Plant	GF	Floor sheeting, pipe insulation, gasket material, boiler/tank insulation, corrugated wall panel, inside boilers several stories high
Ridges#33 Storage Building	GF	None known - new metsal storage building on east side of Plant.
Ridges#34 Ridges Shop (Old Carpenter Shop)	GF	Wall plaster 2nd floor
Ridges#35 (Old Blacksmith Bldg.)	GF	Roof shingles
Ridges#36 Garage	GF	None known
Ridges#37 Printing Shop , Upholstry Shop (Old Laundry Bldg.)	GF	Performed-block pipe insulation, layered pipe insulation and cementitious fitting (some removed in 2000, not all), floor tile, window glazing
Ridges#38 Two Apartments Old Physician Unit (west)	GF	Floor tile & mastic, floor sheeting, duct tape, duct wrap, thermal system insulation (*amount includes both building #38 and #39)
Ridges#39 Two Apartments Old Physician Unit (east)	GF	Floor tile & mastic, floor sheeting, duct tape, duct wrap, thermal system insulation (*amount includes both building #38 and #39)
Ridges#40 Pump House	GF	None known

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys

Ohio University Building Asbestos Summary List

Roofs	GF, RA, RC	Roofing materials are generally not sampled during surveys, since this can damage some roofs. See EHS for details on sampling before any roof work..
Rt. 56 Property (Old Car Dealer/Blue Bldgs.)	GF	None known - abated in 2003. Leased out in 2004.
Ryors	RA	Pipe insulation and fittings, transite wall panels, floor tile, mastic, fire doors
Sargent	RA	Pipe insulation and fittings, transite wall panels, floor tile, mastic, fire doors
Scott Quad	GF	Adhesive for ceiling tile, floor tile & mastic, thermal system insulation
Scripts (old Carnegie)	GF	None known
Seigfred	GF	Floor tile, transite, cementitious fitting insulation, acoustical plaster ceilings, performed block tank insulation, paper shield in dome lights, floor tile, fire doors, vibration joints
Seigfred Sculpture Studio (Foundry)	GF	None known
Shively	RA	Fitting insulation, exhaust stack insulation, floor tile, mastic, fire doors
Sing Tao House (109 S. Court St.)	GF	None known.....abated and renovated in early 90's.
Smith	RA	tank insulation, fitting insulation, exhaust stack insulation, floor tile, mastic, fire doors, transite ceiling & wall panels
Stocker Center	GF	None known
Stores Receiving (old McBee)	GF	Pipe insulation, floor tile/mastic material, tank insulation, transite wall panels (abated in 10/2000 and demolished))
Surface Science Lab (old neutron lab)	GF	None known
Tennis Facility	GF	None known (new 1999)
Tiffin	RA	pipe and duct insulation, transite wall panels, window glazing, floor tile, mastic, fire doors
Treudley	RA	fitting insulation, transite wall panels, floor tile, mastic, fire doors
Trisolini Gallery	GF	Floor tile, pipe insulation, pipe fittings, window caulking, fire doors
True	RA	exhaust stack insulation, tank insulation, fitting insulation, transite ceiling & wall panels, floor tile, mastic, fire doors
Tunnels (Main)	GF	Main tunnels were re- done and acm abated, <u>but there are small stub tunnels that still have some acm, use caution!</u>
Tunnels (Stub)		Foam glass with tar, foam glass with mud fittings, fiberglass insulation w/mud fittings, galbestos panels, preform-block insulation, transite carries piping, tar expansion joints
Tupper	GF	Floor tile & mastic
TV Transmitter Co Rd 19 (off Rt. 56)	GF	floor tile, mastic
Voigt	RA	pipe insulation, tank insulation, transite wall panels, floor tile, mastic, fire doors
Walter Hall Lecture Hall	GF	None known - new in 2004.
Washington	RA	pipe insulation, floor tile, mastic, fire doors
Weld	RA	exhaust stack insulation, tank insulation, fitting insulation, transite ceiling & wall panels, floor tile, mastic, fire doors
Wilson (Campus Green)	GF	Mudded pipe fitting, floor tile & mastic, exterior window caulking, drywall mud

RA = Residence Auxiliary
RC = Regional Campus
GF = General Fund

This is a general listing only!
List last updated on 1/03/2005
See EHS for complete building surveys