

#	ALARM ACTIVITIES ON O. U.'S CAMPUS 2007 Jan. 07-Dec 8' 07
	occupant caused
	malicious false alarm-pull station
	caused fire
	maint.related
1	burned some food which set off the alarm, no fire, advised 911.
2	pull on the 4th floor
3	kitchen ,caused smoke to build up and set off alarm.
4	burnt popcorn in room 6xx. System reset.
5	Malfunction with system.
6	Burnt popcorn.
7	sprinkler monitor and room 1xx. No fire.
8	fire in the dumpster. AFD notified.
9	pulled cover off,only
10	Dumpster fully engulfed
11	rm. 1xx. System malfunction.
12	Burnt popcorn in microwave.
13	burnt popcorn
15	system malfunction
16	system malfunction
17	AFD/270 responded. No fire.
18	smoke detector in room 114 activated (Food Court area)
19	Trouble w/ system.
20	Someone set off fire extinguisher in 2nd floor hallway
21	Burnt popcorn
21	Dust in the ceramics Dept
22	open window caused a sprinkler to freeze and bust in the basement.
23	Pull station activated
24	Burnt popcorn
25	lit a piece of paper in hallway
26	Notified 911 and Life Safety..units adv. Smoke from grill in the food court set the alarm off, no fire.
27	Notified 911 and Life Safety..units adv. Smoke from grill in the food court set the alarm off,
28	Keys put back in lock box.Dispatched 911 & 270. Panel adv. 4th floor pull station in Mod-B activated.System reset.
29	Dispatched 911 & 270. System Malfunction, U-270 trying to reset it.
30	Dispatched 911 & U-270. Panel adv. Room 2xx.
31	Officer reports an audible alarm sounding throughout the building. Officer advises the fire panel is reporting a trouble with the smoke detector in room 2xx. Officer requests additional officers to assist with vacating the building,occupants are refusing to leave. AFD and 270 also notified. AFD later advised to cancel.
32	Notified 911 and emergency maint.;unable to determine what set off alarm,Life Safety was contacted to check system
33	Notified 911 and emergency maint.;system malfunction,270 will call Life Safety back in
34	U-23 & U-270 Responding. Life Safety dispatched and responding. AFD requests building be taken off line and fire watch put in place.
35	alarm went off due to a frozen water line

36	9 hair straightener
37	Burnt popcorn.
38	Water was running into the fire panel
39	Notified 911 and F.M.
40	working on a project
41	Pull station 3rd floor.
42	air handler overheated
43	"Tamper Flow" trouble.
44	Faulty flow device,life safety handling.
45	No fire. 1st floor pullstation activated.
46	burnt toast in the registrars's office break room.
47	... pull station
48	... Trash can had been set on fire
49	sprinkler alarm. 270 adv. Someone turned the valve on in stairwell
50	He thought he saw flames coming from nerw building.space heater on 1st floor.
51	pull station activated lounge 2. male given verbal warning for back inside dorm while alarm
52	elevator was on fire;23 put it out with as fire extinguisher.
53	"Main Tamper" and "Trouble" with exhaust 1 &2.
54	... burned popcorn.
55	smoke detector activated in room 2xx,no fire or smoke
56	"Fire Pump Trouble". System malfunctioned
57	detectors showing trouble contractor working in the area.
58	pull station
59	Smoke detector went off in room 2xx
60	pull station in stairwell
61	Pull station activated on 2nd floor Mod-B.
62	smoke detector in dry storage,room 1xx
63	Pull station activated
64	Custodian activated the alarm while buffing the floor.
65	Main flow sensor # 21.
66	burnt popcorn
68	Burnt popcorn
69	burnt popcorn.
70	A steam leak caused the alarm.
71	malfunction in the air handlers, no 47.
72	Notified 911 and Life Safety. Smoke detector activated in room 7xx, reason unknown
73	ground fault PSR power supply.
74	CHARCOALS IN THE DUMPSTER CAUSING THE FIRE. ADF ARRIVED AND PUT THE FIRE OUT.
75	Fire outside the building in the mulch, fire was contained to the mulch outside.
76	trouble,emergency maintenance notified.
77	..smoke detector in room 305. 0113 AFD reference about alcohol located in the room.
78	Sprinkler system has been acivated also. System malfunction.
79	marijuana confiscated from the room.
80	Air freshener or hair spray. No fire. AFD/270 responded. Reset.

81	Air freshner activated the alarm. No fire. Smoke detector was damaged when residents hit it.
82	burnt food
83	Small fire in the mulch behind the Oasis.
84	fire at the front of the building: adv. 911,AFD
85 Unknown cause. 270/AFD responded.
86	.. Unk cause with smoke detector.
87	Alarm caused by hair spray,no fire or smoke.
88	burned food on the stove, no fire.
89	Pull station activated on the 3rd floor
90	Pull station
91	3rd floor again.
92	Pull station activated on 2nd floor.
93	... dust in the wood shed caused No fire or smoke.
94	Fire panel reports smoke detector in room 3xx activated alarm. Cigar and several empty whiskey bottles located in the room. Residence Life processing the paperwork. AFD also notified and responding
95	AFD also notified and responding, later cancelled. activated pull station on the 3rd floor.
96	Recycle bins has been set on fire. AFD on scene and flushed it.
97	... smoke in the garage and the lobby;fire was located in a dumpster in the garage area,extinguished by AFD.
98	residents regarding open flame. Fire extinguished.{ NOT OU }
98	activated in room 932,unknown cause.
99	AFD/270 responded. Duct detector in equipment room 027. System reset. Malfunction. No 47. Will call Life Safety if alarm activates again.
100	. Steam in 407 set the alarm off,no fire or smoke.
101	4th floor manual pull station activated.
102	elevator malfunctioned in the basement,causing a lot of smoke.
103	room 209.AFD on scene. Alarm panel reports trouble with a smoke detector. system malfunction.
104	Small fire in the mulch outside the building,put out using extinguisher from the cruiser.
105	...keys...Fire alarm system reports an audible alarm sounding throughout the building. 2355 AFD and 270 notified and responding. 0003 AFD and 270 on scene. Alarm due to a malfunction in the system.
106	Adv. 911 an dLife Safety..Mike called and adv. They burned some food;some smoke,but no fire..adv.911
107	Dispatched 911. Burnt popcorn in rm. 4xx System reset.{accodring to RD CM, cause of alarm was burned "Easy Mac" in rm 426,filled rm w/smoke}
108	Dispatched 911 & 270. Caller later adv. Smoke machine set off alarm. Negative C28. system reset.
109	Fire panel reports pull station in Mod 1B activated.
110	AFD/270 responded. Burnt food. No fire.
111	Closed. Very minor. No 47.
112	mulch outside the building is smoldering. put the fire out with the extinguisher near room 1xx.
113	4th Floor. Papers on bulliten board were set on fire sometime
114	burnt food in room 610.
115	hairspray activated the detector.
116	.activated pull station in mod 1B.

117	..keys...Pizza rolls burned in the microwave set SEOMS contacted for female having a seizure.
118	Smoke detector malfunction in rm. 4xx. System reset.
119	cooking and burnt some food. AFD cancelled
120	Someone set cardboard recycle bin on fire. AFD on scene @ 0145.
121	table and mattress on fire in parking lot. Fire put out w/water extinguisher out of lower Seigfred.
122	flame twirler ignited.
123	Burnt toast caused a smoke detector to activate, no fire or smoke.
124	Steam activated the detector in the air handler.
125	...keys...Fire alarm system reports an audible alarm sounding throughout the building. Fire panel reports an activated pull station on the 2nd floor near room 2xx.
126	Building 19 not secure upon arrival. Fire system trouble.
127	3rd Floor Stairwell responded. No fire. Nothing found.
128	James showed normal. No fire signal showing
129	KEYSAFD/270 RESPONDED. MALFUNCTION.
130	Fire alarm in Bromley Hall. Chemical spill occurred in the basement.
131	Contractors set off a smoke detector in the 1st floor mechanical room,no fire.
132	2nd floor smoke detector in SW stairwell. Panel will not reset.
133	FM adv. A painter accid. Set off the alarm;notified 911. Life Safety reset it.
134	smoke machine had set fire alarm off. AFD cancelled.
135	AFD/270 responded. Alarm malfunction.
135	Music 4th Floor-(6-27-07-Fri. 5:44 pm) Smoke and Haze on the floor. No fire found. Custodial staff advised to call if it gets worse. Odor on 2,3, and 4th floor.
136	system troubles, believe contractor may have done something to set off the alarm.
137	Female called 911 to adv. Her cooking set off the alarm..33 reset it.
138	detector was activated in dining hall bathroom,system was reset.
139	fire alarm and water flow were activated. Mechanical issue May receive more system alerts.
140	Contractor possibly set off the alarm drilling on the 2nd floor.
141	Dispatched 911 & 270. . Smoke detector in room 269. Residents had burnt popcorn.
142	Saw dust from the wood shop set the alarm off, no fire.
143	System malfunction. AFD/270 responded. AFD will follow-up. No fire.
144	showing trouble, AFD canceled. Resident painted room and the fumes set off detector. System reset by 270. Res. Life will handle in morning.
145	Dispatched 911. Panel adv. Rm 6xx again.
152	rm. 2xx Resident burned popcorn in room.
153	AFD was enroute;18 adv. It was a trouble alarm,not a fire alarm.
154	alarm was set off by dust or dirt in a 4th. Floor detector.
155	Contractors set off the alarm sawing concrete on the basketball court.
156	possibly set off by air handler malfunction
157	Exhaust fumes from crane that was set up right outside the door set off smoke detector on the ground floor.
158	Fire alarm activated in Shively. Malfunctioning detector in the first floor NW stairwell system has been reset.
159	Notified 911 and emergency maint.;no fire, possibly weather related.

160	Alarm due to malfunction with smoke detector in the northwest stairwell.
161	270 working on the smoke detectors in room 141/142 also.
162	Dry Storage room.Adv. 911 and Life Safety..mgr, adv. They were using steam to clean the restroom and that set the alarm off.
163	Panel showing overflow in room 214. Life Safety notified.
164	AFD/270 RESPONDED. 270 calling in life safety for a system problem. No fire.
165	Room 4xx.AFD/270 RESPONDED. Burnt popcorn. No fire.
166	smoke detector in the attic,was a malfunction.{AFD said duct leak}
167	room 3xx. Alarm activated by burnt popcorn in the microwave.
168	Alarm due to pull station activated near the exit door on the ground floor.
169	room 3xx - AFD/270 responded. Burnt popcorn. No fire.
170	room 1xx,dust set off alarm,AFD was cancelled.
171	adv. Burnt food in rm.
172	...keys...Adv. Pull station near 194. System reset.
173	Smoke detector activated in room 125 laundry room due to a dryer not venting properly. No fire.
174	It's the dryer vent in the laundry room again. RD closed the laundry room until someone can take care of the problem.
175	Mulch is smoldering;extinguished by AFD.
176	Alarm activated by excessive steam in the laundry facility. Window opened and facility closed until problem repaired.
177	smoke detector in the 2nd floor bedroom @ xx Park Place. AFD and unit 270 responding. Alarm activated by faulty detector in the attic. Maintenance will repair in the morning.
178	VENT SYSTEM NOT WORKING PROPERLY-LIFE SAFETY WILL NOTIFY FACILITIES TO REPAIR HOOD SYSTEM.
179	Alarm activated by a faulty smoke detector.
180	Adv. 911 and Life Safety..res. In 2xx burned food, AFD vented the area with a fan.
181	burned food in microwave in room 2xx set off alarm.
182	detector was activated in room 2xx, possibly by cologne.
183	reports malfunction ocured earlier.
184	room 3xx by curling iron.
185	burnt popcorn in room 241 set off the alarm
186	small fire in an outside vent. Officers responded,AFD/270 responded,fire put out.
187	Smoke detector in rm. 3xx.Keyed into room odor of burnt popcorn.
188	Burnt popcorn in room 2xx. No fire. AFD/270 responded. Life Safety called in for the attic problem,by 270.
189	Smoke detector rm. 2xx. Detector malfunction,system reset.
190	AFD/270 responded.Duct 16 in room 0xx. No fire. Alarm reset.
191	air freshner in a restroom.
192	Smoke detector room 3xx.
193	pull station by 2A
194	detector malfunction.
195	Burnt popcorn.
196	pull station activated in the SE stairwell.
197	trouble in the "Elevator equipment room". Officer noticed a scent of smoke in the area. Elevator grounded and power shut off to the elevator.
198	detector malfunction in room 2xx.
199	Residents burnt food in micro,systems reset.

200	Irradiator Area--AFD cleared scene. System restored.
201	Smoke coming out of the heating vent. Adv. to pull a fire alarm and evacuate..notified 911 and Life Safety. FM unit adv. Of a fire in the air handler.
202	...keys... Door to room opened @ 0102-no fire. No entry made. #,# Smoke detector in room 3xx. AFD/270 responded.
203	Notified 911 & 270. Panel adv. Smoke detector in corridor 118. System reset and Life Safety notified
204	Notified 911 and Life Safety; burnt toast in room 7xx set off alarm
205	Notified 911 and Life Safety;burnt popcorn in room 4xx set off alarm
206	Names withheld, UAC and paraphernalia #20 keys removed @ S37 and returned @ S33. Fog machine activated the smoke detector. AFD/270 responded. No fire. Alarm reset. Both residents referred to judiciaries for UAC. One referred for drug paraphernalia.
207	#20 ...keys... AFD/270 responded. Smoke detector activated. No fire.
208	Adv. 911 and 270. missing smoke detector in mechanical rom 105 caused the alarm to go off, no fire or smoke.
209	keys....Dispatched 911 & 270. Panel adv. Rm. 1xx, curling iron & hair spray set off alarm. System reset.
210	OUPD report on Adams missing,from AFD report: Report of alarm sounding at Adams Hall. Upon arrival found alarm was in romm 4xx. OUPD advised alarm was caused by occupant trying to cover up marijuana odor with air freshner.
211	..keys... Notified 911 and Life Safety;burnt food in room 2xx set off the alarm.
212	...keys...AFD/270 responded. Hair straightener set off the alarm. No fire.
209	AFD and Life Safety were notified;exhaust fan malfunctioned allowing smoke to set off a detector
210	Notified 911 and Life Safety;water leak on 2nd floor caused detector to malfunction
211	room 1xx. Alarm system reports an audilbe alarm sounding throughout the building. AFD and unit 270 also notified. Alarm activated due to burnt food.
212	Adv. 911. Life Safety accid. Set the alarm off,no fire. Cancelled AFD.
213	Adv. 911 and Life Safety..units adv. Pull station on 2nd floor was activated,no fire or smoke.
214	RP adv. The alarm is false,was pulled on 2nd floor N end,will supplement #
215	Heater reported in room 1xx as being on fire,but is out at this time. Heater is smoking heavily. Adv. To pull the fire alarm and evacuate the buidling. AFD/270 responded. No fire upon arrival. No fire had occurred after inspection. Source was electrical problem with the thermostat. 270 taking care of the repairs.
216	#1 and #2 contacted @ 2114 hrs. Large door will open w/ 11-A key. 911 dispatched AFD to a fire in the garage area of Weld House. AFD/270 responded. Dumpster was on fire. Fire put out by a sprinkler system. No students displaced, no one hurt. Area secured and water valve located.
217	Notified 911 U-21 adv. Pull station in Mod 1-B, AFD cancelled. System reset.
218	Keys removed,..returned..Dispatched AFD & U-270. Panel adv. Smoke detector rm Residents will be cited for UAC & S69 poss. System reset.
219	Unit 33 adv. Alarm was silenced before he and AFD arrived. Notified 911 and emergency maint.;problem with heating/cooling system caused the alarm to go off.

220	room xxx AFD responded. No fire. Smoke detector in room xxx activated the system. Life Safety responded to check the detector.
221	Adv. 911 and 270. AFD responded. No fire. Pull station on first floor. Mod B, was activated.
222	Smoke detector in room 3xx activated the system. Burnt popcorn activated the detector. No fire. System reset. AFD/270 responded.
223	Dispatched 911 & U-270. Burnt popcorn in rm. 3xx. System reset.
224	Notified 911 and emergency maintenance.;alarm was activated by burnt food in room xxx.
225	keys....Notified 911 and Life Safety;alarm was set off by air freshner in the womens restroom in eth dining hall.
226	AFD/270 responded. Smoke detector in room xxx activated. Malfunction. No fire. Alarm reset.
227	keys....Larry Ervin responding. Dispatched 911. AFD on scene @ 0536. Panel adv. Irradiator alarm. Panel will not clear trouble. Life Safety on call dispatched @ 0550
228	Dispatched 911 & U-270. Units adv. Water leak above rm. xxx. Panel reset.
229	Residence hall and alarm keys....Notified 911 and Life Safety;paint fumes on 5th. Floor set off alarm.
230	Adv. 911 and Life Safety..U-6 is working w/the alarm company on another issue and the system sent fire alarm signals inadvertently...cancelled AFD
231	Notified 911 and Life Safety;contractor working on the second floor set off alarm.
232	Notified 911 and Life Safety;contractor cutting pipe in the basement with a torch set off alarm.
233	Notified 911 and Life Safety;dust from contractor working on the 4th. floor set off alarm.
234	..keys...Notified 911 and Life Safety;burnt popcorn set off alarm
235	Adv. 911 and Life Safety. Jxx Yxxx called 0710 and adv. The propane buffer set the alarm off.adv. 911 and Life Safety.
236	...keys...Adv. 911 and 270..15 adv. A sprinkler pipe in the garage busted.