

# Fire Alarm Systems



## Environmental Health & Safety Guidelines

Replacement and new installation of Fire Alarm Systems

- \* Simplex 4100U Fire Alarm Panel.
- \* Voice Alert System.
- \* Strobe/Speakers—Interior.
- \* Speakers—Exterior (minimum 2 sides of building).
- \* Interior and Exterior Speaker Controls—Switch Selectable.
- \* Shielded Cable—Speaker/Strobes.

EHS will periodically issue guidelines for subjects and situations which affect the safety and health of the campus community. These are not Ohio University policy. They represent best practices and proven methods to reduce incidents.

**You may call Environmental Health and Safety at 593-1666  
Or visit us on the web at [www.ohio.edu/ehs](http://www.ohio.edu/ehs)**

