

# OUTDOOR LIGHTING



## Environmental Health & Safety Guidelines

The following operating guidelines apply to all new construction, renewal of building exteriors, and other outdoor improvements after 11/1/2010.

<b>Area One</b>	<b>Average Levels</b>	<b>Minimum Levels</b>
♦High pedestrian activity	2.5 FC (25 LUX)	.75 FC (8 LUX)
♦High volume parking lots	2.5 FC (25 LUX)	.75 FC (8 LUX)
♦Parking garages	2.5 FC (25 LUX)	.75 FC (8 LUX)

Examples:

- Peden area, Baker Center, Ping Center, Memorial Auditorium, etc
- Convocation Center lot, Peden lot, Baker Center garage, etc

<b>Area Two</b>	<b>Average Levels</b>	<b>Minimum Level</b>
♦Primary walkways	2 FC (20 LUX)	.50 FC (5 LUX)
♦Primary streets	2 FC (20 LUX)	.50 FC (5 LUX)

Examples:

- Main Green Area, Jefferson Hill, Shivley Hall, South Green Front Four, etc
- All named roads

<b>Area Three</b>	<b>Average Levels</b>	<b>Minimum Level</b>
♦Secondary walkways	1 FC (10 LUX)	.25 FC (3LUX)
♦Secondary streets parking lots	1 FC (10 LUX)	.25 FC (3LUX)
♦Other outside use areas	1 FC (10 LUX)	.25 FC (3LUX)

Examples

- East side of Bird Arena, behind Seigfred
- Unnamed roads and alleys

*EHS will periodically issue guidelines for subjects and situations which affect the safety and health of the campus community. These are not Ohio University policy. They represent best practices and proven methods to reduce incidents.*

**You may call Environmental Health and Safety at 593-1666  
Or visit us on the web at [www.ohio.edu/ehs](http://www.ohio.edu/ehs)**

